


HORTON 2024 (4803024) WATER SUPPLY ZONE.

COMMENTARY ON WATER QUALITY

The water supplied to the zone is classified as being moderately soft to slightly hard water, which is river/reservoir derived. As we have a grid system in place whereby we can move water around the Yorkshire region as required, occasionally the hardness of your water may vary.

No fluoride is added to the water. Any fluoride that is there is naturally occurring.

The geographical area covered by this Water Supply Zone is show below:



(Ody) COPYRIGHT STATEMENTS: Based upon Ordnance Survey map data with the permission of the Controller of HMSO, (c) Crown Copyright. Licence No. 100019559. Copyright for additional WSZ boundary data shown on this map rests with Yorkshire Water.

Yorkshire Water Services		Reporting Period: 01-01-2024 to 31-12-2024									
Water Supply Zone: Horton 2024		Population							20180		
ParameterName:	Std	Und Std	Units	No of Samples taken	No of Fails	% Fails	No of Fails (Und)	% Fails (Und)	Min	Mean	Max
Colony Counts After 3 Days At 22øc	-		no'/ml	24	0	0.00%	0	0.00%	0	0	0
E. coli	0		no'/100 ml	60	0	0.00%	0	0.00%	0	0	0
Enterococci	0		no'/100 ml	8	0	0.00%	0	0.00%	0	0	0
Residual Disinfectant - Free	-		mg/l	60	0	0.00%	0	0.00%	0.14	0.53	0.94
Residual Disinfectant - Total	-		mg/l	60	0	0.00%	0	0.00%	0.28	0.64	1.03
Total coliforms(Indicator)	0		no'/100 ml	60	0	0.00%	0	0.00%	0	0	0
1,2 Dichloroethane	3		µg/l	8	0	0.00%	0	0.00% <	0.16 <	0.2 <	0.16
Aluminium	200		µg Al/l	24	0	0.00%	0	0.00% <	8.06 <	16.148	31.3
Ammonium(ammonia and ammonium ions)	0.5		mg NH4/l	24	0	0.00%	0	0.00% <	0.008 <	0.0108	0.034
Antimony	5		µg Sb/l	8	0	0.00%	0	0.00%	0.1	0.1387	0.24
Arsenic	10		µg As/l	8	0	0.00%	0	0.00% <	0.11 <	0.1525	0.19
Benzene	1		µg/l	8	0	0.00%	0	0.00% <	0.06 <	0.06 <	0.06
Benzo 3,4 pyrene	0.01		ug/l	8	0	0.00%	0	0.00% <	0.00042 <	0.0004 <	0.00042
Boron	1		mg B/l	8	0	0.00%	0	0.00% <	0.032 <	0.032 <	0.032
Bromate	10		µg BrO3/l	8	0	0.00%	0	0.00%	0.4	0.5125	0.8
Cadmium	5		µg Cd/l	8	0	0.00%	0	0.00% <	0.03 <	0.0312	0.04
Chloride	250		mg Cl/l	8	0	0.00%	0	0.00%	6.3	7.35	9
Chromium	50		µg Cr/l	8	0	0.00%	0	0.00% <	0.04 <	0.1387	0.2
Colour	20		mg/l Pt/Co scale	24	0	0.00%	0	0.00% <	3 <	3 <	3
Conductivity	2500		µS/cm	24	0	0.00%	0	0.00%	145	189.71	224
Copper	2		mg Cu/l	8	0	0.00%	0	0.00% <	0.0004 <	0.0029	0.0142
Cyanide	50		µg CN/l	8	0	0.00%	0	0.00% <	1.2 <	1.2 <	1.2
Fluoride	1.5		mg F/l	8	0	0.00%	0	0.00% <	0.04 <	0.047	0.06
Hydrogen Ion (pH)	6.5 - 9.5		pH value	24	0	0.00%	0	0.00%	7.22	7.53	7.88
Iron	200		µg Fe/l	24	0	0.00%	0	0.00% <	3.72 <	6.82	30
Lead	10		µg/l	8	0	0.00%	0	0.00% <	0.02 <	0.49	2.63
Manganese	50		µg Mn/l	24	0	0.00%	0	0.00% <	0.3 <	0.57	0.85
Mercury	1		µg Hg/l	8	0	0.00%	0	0.00% <	0.04 <	0.05 <	0.06
Nickel	20		µg Ni/l	8	0	0.00%	0	0.00%	0.56	0.978	1.84
Nitrate	50		mg NO3/l	8	0	0.00%	0	0.00% <	2.13 <	2.2637	2.88
Nitrite - Consumer's Taps	0.5		mg/l NO2	8	0	0.00%	0	0.00% <	0.002 <	0.0021 <	0.003

Yorkshire Water Services		Reporting Period: 01-01-2024 to 31-12-2024									
Water Supply Zone: Horton 2024		Population							20180		
ParameterName:	Std	Und Std	Units	No of Samples taken	No of Fails	% Fails	No of Fails (Und)	% Fails (Und)	Min	Mean	Max
Nitrite/ Nitrate formula	1		mg/l	8	0	0.00%	0	0.00%	0	0.0138	0.06
Odour	0		dilution number	24	0	0.00%	0	0.00%	0	0	0
Polycyclic Aromatic Hydrocarbons (PAHs)	0.1		µg/l	8	0	0.00%	0	0.00%	0	0	0
Selenium	10		µg Se/l	8	0	0.00%	0	0.00% <	0.08 <	0.23 <	0.32
Sodium	200		mg Na/l	8	0	0.00%	0	0.00%	6.07	6.56	6.93
Sulphate	250		mg SO4/l	8	0	0.00%	0	0.00%	29.9	41.975	48.9
Taste	0		dilution number	24	0	0.00%	0	0.00%	0	0	0
Tetrachloroethene/Trichlorethene - Sum	10		µg/l	8	0	0.00%	0	0.00%	0	0	0
Tetrachloromethane	3		µg/l	8	0	0.00%	0	0.00% <	0.16 <	0.1612	0.17
Total organic carbon	-		mg C/l	8	0	0.00%	0	0.00%	1.37	1.74	2.29
Total Trihalomethanes (THM's)	100		µg/l	8	0	0.00%	0	0.00%	21.36	38.985	55.31
Turbidity	4		NTU	24	0	0.00%	0	0.00% <	0.07 <	0.159	0.3
Calcium	-		mg Ca/l	8	0	0.00%	0	0.00%	24.3	34.575	41.9
Magnesium	-		mg Mg/l	8	0	0.00%	0	0.00%	1.44	1.8425	2.1
Total Hardness	-		mg Ca/l	8	0	0.00%	0	0.00%	26.6	37.6125	45.2
2,4,5-T	0.1		µg/l	8	0	0.00%	0	0.00% <	0.013 <	0.0135 <	0.015
2,4-D	0.1		µg/l	8	0	0.00%	0	0.00% <	0.01 <	0.0102 <	0.011
2,4-DB	0.1		µg/l	8	0	0.00%	0	0.00% <	0.01 <	0.0115 <	0.012
Aldrin	0.03		µg/l	8	0	0.00%	0	0.00% <	0.008 <	0.008 <	0.008
Atrazine	0.1		µg/l	8	0	0.00%	0	0.00% <	0.006 <	0.006 <	0.006
Azoxystrobin	0.1		µg/l	8	0	0.00%	0	0.00% <	0.006 <	0.006 <	0.006
Bentazone	0.1		µg/l	8	0	0.00%	0	0.00% <	0.004 <	0.0042 <	0.005
Bixafen	0.1		µg/l	8	0	0.00%	0	0.00% <	0.012 <	0.012 <	0.012
Boscalid	0.1		µg/l	8	0	0.00%	0	0.00% <	0.008 <	0.008 <	0.008
Bromacil	0.1		µg/l	8	0	0.00%	0	0.00% <	0.011 <	0.011 <	0.011
Bromoxynil	0.1		µg/l	8	0	0.00%	0	0.00% <	0.007 <	0.0078 <	0.01
Carbetamide	0.1		µg/l	8	0	0.00%	0	0.00% <	0.009 <	0.0101 <	0.018
Chlormequat	0.1		µg/l	8	0	0.00%	0	0.00% <	0.008 <	0.008 <	0.008
Chlorpropham	0.1		µg/l	8	0	0.00%	0	0.00% <	0.005 <	0.008 <	0.009
Chlorpyrifos	0.1		µg/l	8	0	0.00%	0	0.00% <	0.008 <	0.008 <	0.008
Chlortoluron	0.1		µg/l	8	0	0.00%	0	0.00% <	0.005 <	0.005 <	0.005
Clomazone	0.1		µg/l	8	0	0.00%	0	0.00% <	0.007 <	0.007 <	0.007

ParameterName:	Std	Und Std	Units	No of Samples	No of Fails	% Fails	Population		% Fails	20180		
							No of Fails	(Und)		Min	Mean	Max
				taken					(Und)			
Clopyralid	0.1		µg/l	8	0	0.00%	0	0.00%	<	0.011 <	0.0117 <	0.012
Cyanazine	0.1		µg/l	8	0	0.00%	0	0.00%	<	0.007 <	0.007 <	0.007
Cypermethrin	0.1		µg/l	8	0	0.00%	0	0.00%	<	0.008 <	0.008 <	0.008
Cyproconazole	0.1		µg/l	8	0	0.00%	0	0.00%	<	0.006 <	0.006 <	0.006
Diazinon	0.1		µg/l	8	0	0.00%	0	0.00%	<	0.007 <	0.007 <	0.007
Dicamba	0.1		µg/l	8	0	0.00%	0	0.00%	<	0.011 <	0.0112 <	0.012
Dichlobenil	0.1		µg/l	8	0	0.00%	0	0.00%	<	0.004 <	0.004 <	0.004
Dichlorprop	0.1		µg/l	8	0	0.00%	0	0.00%	<	0.006 <	0.007 <	0.01
Dieldrin	0.03		µg/l	8	0	0.00%	0	0.00%	<	0.009 <	0.009 <	0.009
Difenconazole	0.1		µg/l	8	0	0.00%	0	0.00%	<	0.009 <	0.009 <	0.009
Diffenican	0.1		µg/l	8	0	0.00%	0	0.00%	<	0.009 <	0.009 <	0.009
Diuron	0.1		µg/l	8	0	0.00%	0	0.00%	<	0.009 <	0.009 <	0.009
Epoxiconazole	0.1		µg/l	8	0	0.00%	0	0.00%	<	0.006 <	0.006 <	0.006
EPTC	0.1		µg/l	8	0	0.00%	0	0.00%	<	0.022 <	0.022 <	0.022
Flufenacet	0.1		µg/l	8	0	0.00%	0	0.00%	<	0.008 <	0.008 <	0.008
Fluroxypyr	0.1		µg/l	8	0	0.00%	0	0.00%	<	0.008 <	0.0102 <	0.011
Flurtamone	0.1		µg/l	8	0	0.00%	0	0.00%	<	0.007 <	0.007 <	0.007
Flusilazole	0.1		µg/l	8	0	0.00%	0	0.00%	<	0.009 <	0.009 <	0.009
Flutriafol	0.1		µg/l	8	0	0.00%	0	0.00%	<	0.005 <	0.005 <	0.005
Fluxapyroxad	0.1		µg/l	8	0	0.00%	0	0.00%	<	0.01 <	0.01 <	0.01
Gamma-HCH (Lindane)	0.1		µg/l	8	0	0.00%	0	0.00%	<	0.005 <	0.005 <	0.005
Heptachlor	0.03		µg/l	8	0	0.00%	0	0.00%	<	0.005 <	0.005 <	0.005
Heptachlor epoxide	0.03		µg/l	8	0	0.00%	0	0.00%	<	0.007 <	0.007 <	0.007
Imazapyr	0.1		µg/l	8	0	0.00%	0	0.00%	<	0.004 <	0.0055 <	0.006
Ioxynil	0.1		µg/l	8	0	0.00%	0	0.00%	<	0.004 <	0.0042 <	0.005
Isoproturon	0.1		µg/l	8	0	0.00%	0	0.00%	<	0.005 <	0.005 <	0.005
Linuron	0.1		µg/l	8	0	0.00%	0	0.00%	<	0.009 <	0.009 <	0.009
MCPA	0.1		µg/l	8	0	0.00%	0	0.00%	<	0.006 <	0.0082	0.014
Mecoprop-P	0.1		µg/l	8	0	0.00%	0	0.00%	<	0.009 <	0.0098 <	0.01
Mepiquat chloride	0.1		µg/l	8	0	0.00%	0	0.00%	<	0.008 <	0.008 <	0.008
Metaldhyde	0.1		µg/l	8	0	0.00%	0	0.00%	<	0.006 <	0.0062	0.008
Metamitron	0.1		µg/l	8	0	0.00%	0	0.00%	<	0.008 <	0.008 <	0.008
Metazachlor	0.1		µg/l	8	0	0.00%	0	0.00%	<	0.005 <	0.005 <	0.005
Metobromuron	0.1		µg/l	8	0	0.00%	0	0.00%	<	0.01 <	0.01 <	0.01

Horton 2024				Population				20180			
ParameterName:	Std	Und Std	Units	No of Samples taken	No of Fails	% Fails	No of Fails (Und)	% Fails (Und)	Min	Mean	Max
Monuron	0.1		µg/l	8	0	0.00%	0	0.00% <	0.005 <	0.005 <	0.005
op'-DDD (TDE)	0.1		µg/l	8	0	0.00%	0	0.00% <	0.005 <	0.005 <	0.005
op'-DDE	0.1		µg/l	8	0	0.00%	0	0.00% <	0.005 <	0.005 <	0.005
op'-DDT	0.1		µg/l	8	0	0.00%	0	0.00% <	0.004 <	0.004 <	0.004
Oxadixyl	0.1		µg/l	8	0	0.00%	0	0.00% <	0.012 <	0.012 <	0.012
Pendimethalin	0.1		µg/l	8	0	0.00%	0	0.00% <	0.009 <	0.009 <	0.009
Pesticides - Total Substances	0.5		µg/l	8	0	0.00%	0	0.00%	0	0.0028	0.014
pp'-DDD (TDE)	0.1		µg/l	8	0	0.00%	0	0.00% <	0.005 <	0.005 <	0.005
pp'-DDE	0.1		µg/l	8	0	0.00%	0	0.00% <	0.005 <	0.005 <	0.005
pp'-DDT	0.1		µg/l	8	0	0.00%	0	0.00% <	0.004 <	0.004 <	0.004
Propachlor	0.1		µg/l	8	0	0.00%	0	0.00% <	0.007 <	0.007 <	0.007
Propamocarb	0.1		µg/l	8	0	0.00%	0	0.00% <	0.004 <	0.0045 <	0.006
Propham	0.1		µg/l	8	0	0.00%	0	0.00% <	0.005 <	0.005 <	0.005
Propiconazole	0.1		µg/l	8	0	0.00%	0	0.00% <	0.009 <	0.009 <	0.009
Propyzamide	0.1		µg/l	8	0	0.00%	0	0.00% <	0.009 <	0.009 <	0.009
Prosulfocarb	0.1		µg/l	8	0	0.00%	0	0.00% <	0.006 <	0.006 <	0.006
Prothioconazole-desthio	0.1		µg/l	8	0	0.00%	0	0.00% <	0.007 <	0.007 <	0.007
Quinmerac	0.1		µg/l	8	0	0.00%	0	0.00% <	0.006 <	0.0067 <	0.012
Simazine	0.1		µg/l	8	0	0.00%	0	0.00% <	0.005 <	0.005 <	0.005
Tebuconazole	0.1		µg/l	8	0	0.00%	0	0.00% <	0.006 <	0.006 <	0.006
Tri-allate	0.1		µg/l	8	0	0.00%	0	0.00% <	0.006 <	0.006 <	0.006
Trichlopyr	0.1		µg/l	8	0	0.00%	0	0.00% <	0.016 <	0.0182 <	0.019
Trietazine	0.1		µg/l	8	0	0.00%	0	0.00% <	0.005 <	0.005 <	0.005

- Notes:**
- 1) Qualified values are taken at face value in all calculations.
 - 2) Any infringements of the regulatory standard are thoroughly investigated and are reported to the Drinking Water Inspectorate (DWI), with remedial actions put in place where necessary.
 - 3) Details of undertakings and notices (Improvement programmes) applicable can be obtained from the DWI website: [Yorkshire Water Improvement Programmes - Drinking Water Inspectorate](#)